

OFFICE OF THE EXECUTIVE ENGINEER
Building Division, Jamshedpur


Letter No. 89.....


Jamshedpur /Dated 20.02.2021


TO WHOM IT MAY CONCERN

This is to certify that Construction of Building of *JAMSHEDPUR PUBLIC SCHOOL*, Panchavati Road, New Baridih, Jamshedpur-831017 is found structurally safe to run the school.

The above School was inspected on 18th February 2021 and was found running in a well constructed and safe building in good condition.


Junior Engineer
Building Sub Division
Jamshedpur


Assistant Engineer
Building Sub Division
Jamshedpur


Executive Engineer
Building Division
Jamshedpur



Jamshedpur Notified Area Committee, Jamshedpur

New Kalimati Road, Sakchi-831001

E-mail ID-jnacpr@gmail.com




Letter no. 2591

Date: 25/11/2020


Certificate for safe drinking Water and Sanitation

It is certified that an inspection team headed by Mr. Sandeep Kumar, City Manager from Jamshedpur Notified Area Committee inspected the Jamshedpur Public School, Panchavati Road, New Baridih, Jamshedpur- 831017, on 24-11-2020 and found that Jamshedpur Public School, Panchavati Road, New Baridih, Jamshedpur - 831017, has safe drinking water facilities for the students and members of the staff of the institution and is maintaining the hygienic condition in the School. The above valid for period of 24-11-2020 to 23-11-2021.


27/11/2020

City Manager,

Jamshedpur Notified Area Committee,
Jamshedpur


27/11/2020

Special Officer,

Jamshedpur Notified Area Committee,
Jamshedpur.



FIRE ALARM & PROTECTION SYSTEM

HANDING OVER DOCUMENTS

CLIENT:

JAMSHEDPUR PUBLIC SCHOOL
PANCHAVATI ROAD, NEW BARIDIH
JAMSHEDPUR

FIRE CONTRACTOR:

IS FYTECH FIRE PROTECTION SYSTEMS PVT.LTD.

29, GOVINDNAGAR, ALLAHABAD BUILDING,
SECOND FLOOR, KADMA
JAMSHEDPUR - 831005



HANDING OVER PROTOCOL DOCUMENT

PROJECT : JAMSHEDPUR PUBLIC SCHOOL

CONTRACTOR : IS FYTECH FIRE PROTECTION SYSTEMS PVT. LTD.

SYSTEM INSTALLED : FIRE DETECTION ALARM & PROTECTION SYSTEM

Date of System Handing Over : 30.01.2021

Time : 11.30 AM

Work Order Ref No. & Date : JPS/001/20-21 DATED 7.11.2020

Work Start Date : 15.11.2020

Work Completion Date : 27.01.2021

SL.NO.	SYSTEM INSTALLED	QTY	YES NO		OBSERVATION & REMARKS	Name of the Attendees :
			YES	NO		
A. WET RISER CUM DOWN COMMER SYSTEM						
1	Terrace Pump 900 LPM 45 Mtrs. Head	1	✓			MR. VINOD
2	Main Pump 2280 LPM (Hydrant System)	1	✓			ALL STAFF
3	Jockey Pump 180 LPM	1	✓			FYTECH TEAM
4	MCC Panel	1	✓		Satisfactory	
5	Internal Hudrant System	1	✓			
6	Yard Protection with Fire Brigade Inlet	1	✓			
C FIRE ALARM SYSTEM						
1	Conventional System	LOT	✓			
D FIRE EXTINGUISHERS						
1	CO2 Fire Extinguisher	LOT	✓			
2	ABC Fire Extinguisher		✓			
E TRAINING						
1	All Staff including Security	LOT	✓			

Systems installed were tested & demonstrated in presence of : Mr.Harish Singh / Mr.Ashok

JAMSHEDPUR PUBLIC SCHOOL



IS FYTECH FIRE PROTECTION SYSTEMS PVT. LTD.