



To,
Jamshedpur Public school
Baridih
Jamshedpur

WMD/LAB/TL-35/ 6 04 /25

Date: 09/09/25

Sub : Drinking Water Quality of your Institution

Dear Sir/Madam


Water samples were received on 2 .09.25 for analysis of the water quality at our laboratory. The water quality of the samples was found to be satisfactory. Chemical & Bacteriological analysis report is appended below.

Chemical & Bacteriological analysis report.

Sl. No.	Parameters	Source	Standards / Norms	
		Drinking water tap	World Health Organization (WHO)	Bureau of Indian Standards (BIS)
1	Turbidity (NTU)	0.7	≤ 1.0	≤ 1.0 (Acceptable) ≤ 5.0 (Permissible)
2	pH	7.4	6.5-8.5	6.5-8.5
3	Free chlorine(mg/l)	0.2	≥ 0.2	≥ 0.2
4	Total Coliforms/100ml	Absent	Absent	Absent
5	E. coli/100ml	Absent	Absent	Absent

Thank you and we always assure you of our best services.

Yours Sincerely,


Sr Manager/Manager
Town Laboratory, Waterworks.
Water & Wastewater Services.

TATA STEEL UTILITIES AND INFRASTRUCTURE SERVICES LIMITED
(Formerly Jamshedpur Utilities & Services Company Limited)

Registered Office Sakchi Boulevard Road Northern Town Bistupur Jamshedpur 831 001 India
Tel 91 657 6652101 Fax 91 657 2424219
Corporate Identity Number U45200JH2003PLC010315
Website www.tatasteeluisl.com



Jamshedpur Notified Area Committee, Jamshedpur

New Kalimati Road, Sakchi-831001
E-mail ID-jnacjsr@gmail.com



Letter no:.....
1570

Date:.....
16.06.2023

Certificate for Safe Drinking Water & Sanitary Condition

It is certified that an inspection team headed by **Ms. Christina Kachhap, City Manager** from Sanitation department, Jamshedpur Notified Area Committee inspected the **JAMSHEDPUR PUBLIC SCHOOL, Panchavati, New Baridih, Jamshedpur- 831017** on 15.06.2023 and found that the **JAMSHEDPUR PUBLIC SCHOOL, Panchavati, New Baridih, Jamshedpur- 831017** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of 16.06.2023 to 15.06.2024.

Christina K
16/06/2023

City Manager,
Jamshedpur Notified Area Committee,
Jamshedpur

[Signature]
16/6/23

Special Officer,
Jamshedpur Notified Area Committee,
Jamshedpur



To,

JAMSHEDPUR PUBLIC SCHOOL,
Panchavati, New Baridih, Jamshedpur- 831017